

Appendix 5 – Referral Comments

<i>Type of Referral</i>	<i>Responses</i>
Internal	
Infrastructure Planning Unit	No objection subject to conditions.
Traffic and Transport Unit	No objection to proposal. Plants within the proposed landscaping areas along the accessway should be less than 600mm in height to allow vehicles to overhang during manoeuvring. The proposed location of the two visitor car parking spaces may not be clearly visible to visitors entering the site.