



NOTES

1. CONDUITS FOR GAS, WATER, ELECTRICITY AND TELECOM SERVICES TO BE LOCATED CLEAR OF PAVEMENT AND THE SUBSURFACE DRAIN.
2. REFER TO BACKFILL REQUIREMENTS PER MCC 704.
3. MINIMUM REQUIREMENTS FROM THE FINISH PAVEMENT LEVEL, CAPPING LAYER AND SUBSURFACE DRAIN HAVE TO BE MET, OTHERWISE SERVICE CONDUIT TO BE LOCATED MIN 100MM BELOW THE BEDDING OF SUBSURFACE DRAIN

17/11/2017 2:06:17 PM

ISSUE	APP'D	DATE	AMENDMENT
E			
D			
C	M.H	12/16	REVISED DRAWING NUMBER
B	M.H	06/11	RELOCATED SUBSURFACE DRAIN TO THE CAPPING LAYER
A	V.C.D	04/09	REVIEWED AND UPDATED 2009 STANDARD DRAWINGS

GENERAL NOTES



DESIGN	B.SELL
DRAWN	B.SELL
CHECKED	M.HUTCHINSON
DATE	JUN 11

PROJECT	STANDARD DRAWING - MCC 206	
DETAILS	SERVICES UTILITIES DETAIL	

N.T.S.		
SHEET	1 OF 1	PAPER A4
DRAWING No.		REV B
FILE NAME	MCC 206 - SERVICES UTILITIES DETAIL.DWG	